



# Stormwater Infiltration Feature Inspection Form

OFFICE USE ONLY  
SWP \_\_\_\_\_

**Submit this form by June 1<sup>st</sup> each year**

**Submit via email:**

[stormwater@arroyogrande.org](mailto:stormwater@arroyogrande.org)

**Submit by mail:**

Attn: City Engineer, Community Development  
300 East Branch St  
Arroyo Grande, CA 93420

<b>Inspection Details:</b>	Inspection Date:	Inspector Name:	
	BMP# Inspected:		
	BMP Type: <input type="checkbox"/> Dry Basin <input type="checkbox"/> Infiltration Feature/Basin		
	Inspection Type: <input type="checkbox"/> Pre-Rain <input type="checkbox"/> Monthly <input type="checkbox"/> Semi-Annually <input type="checkbox"/> Annually		
<b>Infiltration Rate:</b>	<input type="checkbox"/> No standing water visible 24-hours following 0.50" storm event.	<input type="checkbox"/> No standing water visible 72 hours following 0.50" storm event.	<input type="checkbox"/> Standing water present longer than 72 hours following 0.50" storm event.
<b>Visual Assessment of Inlets and Outlets:</b>	<input type="checkbox"/> Clear of sediment and debris, no obstructions. No maintenance needed.	<input type="checkbox"/> Some accumulation of sediment or debris, minor maintenance needed.	<input type="checkbox"/> Significant blockage with sediment and debris. Maintenance required.
<b>Sediment or Particle Accumulation</b>	<input type="checkbox"/> Sediment/particulate accumulation less than 1.0". No impacts to infiltration.	<input type="checkbox"/> Sediment/particulate accumulation less than 2.0".	<input type="checkbox"/> Sediment/particulate accumulation greater than 2.0". Cleanout is required.
<b>Surface Layer Condition</b>	<input type="checkbox"/> No visible loss of cover/infiltration media (rocks, gravel, etc.). No rill erosion or scour observed around cover media.	<input type="checkbox"/> Cover media requires infill or repair <b>or</b> minor erosion is visible around media.	<input type="checkbox"/> Cover media (rock, gravel, etc.) requires replacement or repair. Rill erosion evident in BMP. Maintenance required.
<b>Debris or Litter:</b>	<input type="checkbox"/> No debris, litter, or evidence of illicit dumping.	<input type="checkbox"/> Small amount of debris, litter. Debris and litter removed at the time of inspection.	<input type="checkbox"/> Debris and litter present in significant quantities. Evidence of illicit dumping. Removal or repair required.

